

# Grid Supply Point Summary Sheet

UK Power Networks - EPN - November 2021

## Appendix G Summary

Please note that the information provided here is correct as of the date and time uploaded. Responses are updated on a monthly basis and are intended to be indicative only.

Grid Supply Point	Part 1 (MW)	Part 2 (MW)	Part 3 (MW)	Part 4 (MW)	Part 5 (MW)	Total Aggregated Developer Capacity (MW)	Connection Asset Reverse Power Limits (MVA)	Fault Level headroom (kA)	Appendix G date
Amersham	13.2	225.8	0	0	TBA	128	240	TBA	November 2021 <sup>Note 1</sup>
Braintree	25.4	177.6	0	0	36.1	239.1	240	1.53	November 2021 <sup>Note 4</sup>
Bramford	641.8	489.1	0	862	TBA	1762.8	720	TBA	November 2021 <sup>Note 1&amp;3</sup>
Burwell	235.3	158.9	0	466.9	TBA	738	480	TBA	November 2021 <sup>Note 1&amp;3</sup>
Eaton Socon	207	59.4	0	685.3	TBA	557.3	240	TBA	November 2021 <sup>Note 1&amp;3</sup>
Elstree	26.9	240.1	0	0	24	291.0	360	3.0	November 2021
Norwich Main	1025.2	346.6	0	0	TBA	1117.9	720	TBA	November 2021 <sup>Note 1</sup>
Pelham	148.2	713.2	0	0	TBA	602.86	240	TBA	November 2021 <sup>Note 4</sup>
Rayleigh	140.2	808.7	0	0	TBA	770.6	480	TBA	November 2021 <sup>Note 4</sup>
Rye House	27.0	260.2	0	0	TBA	199.8	240	TBA	November 2021 <sup>Note 1</sup>
Sundon	182.1	802.8	0	0	TBA	790.4	480	TBA	November 2021 <sup>Note 1</sup>
Tilbury SGT 1&7 / 2&8	112.4	318.1	0	0	TBA / 12	469.3	240 / 240	TBA	November 2021 <sup>Note 1</sup>
Tottenham	94.7	73.1	0	0	46.9	214.7	420	2.97	November 2021
Walpole	1391.9	690.4	0	0	TBA	TBA	TBA	TBA	November 2021 <sup>Note 1</sup>
Warley	48.2	328.3	0	0	31.1	407.6	240	2.29	November 2021 <sup>Note 2</sup>
Watford South	2.2	2	0	0	115.3	119.5	420	3.3	November 2021
West Thurrock	21.5	49.9	0	0	TBA	TBA	TBA	TBA	November 2021 <sup>Note 1</sup>
Wymondley	227.8	363.9	0	0	TBA	465.32	240	TBA	November 2021 <sup>Note 4</sup>

Note 1 - Connections at this GSP are subject to Project Progression or Modification Application submission as the Materiality Headroom and/or Fault Level Headroom has been exceeded.

Note 2 - Project progression currently in progress.

Note 3 - Project Progression currently in progress. Ongoing negotiations with NG regarding further capacity.

Note 4 - Project Progression currently in progress, expected December 2021

# Grid Supply Point Summary Sheet

UK Power Networks - EPN - November 2021



**Part 1 - Existing Embedded Power Stations** connected to the Distribution System

**Part 2 - Developer Capacity** for Relevant Embedded Power Stations connected and to be connected to the Distribution System where Site Specific Requirements (as specified in Clause 11 of the Bilateral Connection Agreement) shall apply.

**Part 3 - Developer Capacity subject to Interim Restrictions on Availability** (as specified in Clause 12 of the Bilateral Connection Agreement), the Site Specific Requirements (as specified in Clause 11 of the Bilateral Connection Agreement) and the requirements of Appendix D shall apply.

**Part 4 - Developer Capacity for Relevant Embedded Power Stations to be connected** to the Distribution System following completion of works (as specified in the Construction Agreement) and Site Specific Requirements (as specified in Clause 11 of the Bilateral Connection Agreement) shall apply.

**Part 5 - Materiality & Wider System Limits**