

Grid Supply Point Summary Sheet

UK Power Networks – EPN - May 2021

Appendix G Summary

Please note that the information provided here is correct as of the date and time uploaded. Responses are updated on a monthly basis and are intended to be indicative only.

Grid Supply Point	Part 1 (MW)	Part 2 (MW)	Part 3 (MW)	Part 4 (MW)	Part 5 (MW)	Total Aggregated Developer Capacity (MW)	Connection Asset Reverse Power Limits (MVA)	Fault Level headroom (kA)	Appendix G date
Amersham	13.2	114.8	0	0	0	128	240	2.27	May 2019 ^{Note 1}
Braintree	25.4	177.6	0	0	36.1	239.1	240	1.5	April 2021 ^{Note 1}
Bramford	643	490.2	0	0	1.86	1135	720	2.74	Mar 2021 ^{Note 1}
Burwell	235.3	92.6	0	0	39.3	367.2	240	2.9	Jan 2021 ^{Note 1&3}
Eaton Socon	219.5	66.2	0	0	0	285.7	240	3.0	May 2019 ^{Note 1&4}
Elstree	28.2	234.3	0	0	28.5	291.0	360	2.82	May 2021
Norwich Main	1026.2	91.2	0	0	0.5	1117.9	720	2.5	April 2021 ^{Note 1}
Pelham	148.7	265.5	0	0	7.4	421.6	240	3.0	Mar 2021 ^{Note 1&2}
Rayleigh	140.2	629.5	0	0	0.9	770.6	480	2.28	April 2021 ^{Note 1}
Rye House	30.3	119.3	0	0	50.2	199.8	240	3.0	Nov 2020 ^{Note 1}
Sundon	186	554.4	0	0	50	790.4	480	0	Mar 2021 ^{Note 1&2}
Tilbury SGT 1&7 / 2&8	115.2	268.2	0	0	41 / 12	469.3	240 / 240	2.0	May 2021
Tottenham	94.7	71.1	0	0	48.9	214.7	420	3.0	May 2021
Walpole	N/A This site was not covered by Appendix G trial process								
Warley	54.2	328.3	0	0	25.1	407.6	240	2.3	April 2021 ^{Note 1}
Watford South	2.2	2	0	0	115.3	119.5	420	3.3	May 2021
West Thurrock	N/A This site was not covered by Appendix G trial process								
Wymondley	227.8	101	0	0	50	378.8	240	3.0	Mar 2021 ^{Note 1&2}

Note 1 - Connections at this GSP are subject to Project Progression or Modification Application submission as the Materiality Headroom and/or Fault Level Headroom has been exceeded.

Note 2 - Project progression currently in progress.

Note 3 – Project Progression currently in progress, expected June 2021

Note 4 – Project Progression currently in progress, expected August 2021

Grid Supply Point Summary Sheet

UK Power Networks – EPN - May 2021



Part 1 – Existing Embedded Power Stations connected to the Distribution System

Part 2 – Developer Capacity for Relevant Embedded Power Stations connected and to be connected to the Distribution System where Site Specific Requirements (as specified in Clause 11 of the Bilateral Connection Agreement) shall apply.

Part 3 – Developer Capacity subject to Interim Restrictions on Availability (as specified in Clause 12 of the Bilateral Connection Agreement), the Site Specific Requirements (as specified in Clause 11 of the Bilateral Connection Agreement) and the requirements of Appendix D shall apply.

Part 4 – Developer Capacity for Relevant Embedded Power Stations to be connected to the Distribution System following completion of works (as specified in the Construction Agreement) and Site Specific Requirements (as specified in Clause 11 of the Bilateral Connection Agreement) shall apply.

Part 5 - Materiality & Wider System Limits